

Fire Marshal:
Roger Esparza

Administrative Assistant:
inspections@epcountyesd2.org



Office: (915) 851-0304
Fax: (915) 851-9000

Deputy Fire Marshals:
Joe Saucedo
Juan Medina

EL PASO COUNTY E.S.D. #2 -- FIRE MARSHAL'S OFFICE Fire Alarm Plan

Submittal Requirements

Fire Alarm Systems installed within El Paso County ESD #2 territory shall meet all the requirements of the 2015 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final systems testing and inspections will be witnessed by the El Paso County ESD #2 Fire Marshal's Office.

The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

- Permit Application
- Current copy of license issued by The State of Texas Fire Marshal (1 copy)
- System Designer
- Contractor/Company
- Installers
- Submittal Packet (1 copy)
- System Design Description
- Manufacturer's Product Information Sheets of Listed Devices
- Battery Calculations
- Voltage Drop Calculations
- Wiring Calculations
- Riser Diagram
- List of materials

- ___ Addressable Device List/Zone Legend
- ___ List Primary and Secondary Power
- ___ 1/8" Scaled Plans (3 copies)
- ___ Legend
- ___ North Arrow
- ___ Floor Plans Drawn that are free extraneous information
- ___ All Rooms Labeled for intended use
- ___ Separate Circuit Wiring (not conduit) Diagrams for Initiating and Indicating Circuits
- ___ Completed Device-to-Device wiring including End-Of-Line Resistors where applicable
- ___ Device Address Numbers
- ___ System Designers Stamp with Wet Signature
- ___ Modification Permit (up to 10 devices)
- ___ Permit Application
- ___ Copy of Licenses
- ___ Plans 1/8" scale, 2 copies, stamped and wet signed
- ___ Legend showing existing, relocated or additional devices
- ___ Cut sheets for each new device or piece of equipment

Required Inspections

- ___ Pull stations
- ___ Smoke Detection (with smoke)
- ___ Heat Detection (with heat)
- ___ Audio Visual Devices
- ___ Visual Devices
- ___ Monitoring Capabilities

____ Other systems tied to system

Plans review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$71.00 per hour will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner.

INSTALLATION/MODIFICATION PERMIT AND AN APPROVED SET OF PLANS SHALL REMAIN AT THE JOB SITE AND PROVIDED TO INSPECTORS UPON REQUEST.